



**RFQ REFERENCE: ATNS/EP/RFQ003/2023/24\_ UPS**

**APPOINTMENT OF AN EXPERIENCED SERVICE PROVIDER FOR THE SUPPLY, DELIVERY, INSTALLATION AND COMMISSIONING OF 10 KVA, 3HR BACK UP LITHIUM ION, SINGLE PHASE UNINTERRUPTABLE POWER SUPPLY (UPS) FOR ATNS NORTHERN WAM SITES.**

**QUESTIONS AND ANSWERS ARISING FROM THE COMPULSORY VIRTUAL BRIEFING SESSION HELD ON 07<sup>th</sup> JUNE 2023.**

**Q: Load size in Watts?**

A: The load of the site combined is = 8 280 W

**Q: Site Size**

A(s):

- The internal dimensions of the site shelter are 1040 mm x 1200 mm.
- Inside the shelter there is a 600 mm x 600 mm floor standing cabinet
- This gives you an available floor space of 400mm x 1200 mm around the cabinet.
- The supplier is free to consider a floor standing UPS or mounting solution should they deem possible. A survey will be allowed to successfully bidder before installation.



Possible Wall mounting spaces

Maximum of 400 mm x 1200 mm space

The 600 mm x 600 mm standing floor cabinet.



The DB is located inside the shelter and the available space shown above, if the bidder will require more space arrangement of an addition DB shall be made by the Bidder.

